

Indorama Ventures Fibers Germany GmbH

Trademark Service Max-Fischer-Str. 11 86399 Bobingen, Germany

trademarkservice.IVFG@de.indorama.net Tel. +49 8234 9688 1673

www.indoramaventures.com



Approval of the Trademark Trevira CS®

MARIO SIRTORI S.P.A via Papa Giovanni XXIII n 10 23845 Costa Masnaga Italy

 Application No.:
 200881.1

 Date of issue:
 21.07.2025

 Valid until:
 21.01.2026

Article name: ESKIMO CS

Color:

End use: Drapes

Upholstery fabrics

Square weight (g/m²): 660

According to customer specification

Composition of the raw materials: 100% Polyester Composition of the fabric: 100% Trevira CS

The article ESKIMO CS has been tested under the Trevira trademark application no. 200881 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-503 (Brûleur électrique) and thus also meets the requirements for class M1 according to NF P 92-504, 92-505 and 92-507.

The article meets the requirements according to EN 1021-1 and -2:2014 in conjunction with polyurethan foams with a density of more than 30 kg/m^3 .

The article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 10 January 2024.

The article can meet the requirements according to California TB 117-2013, section 1 - cover fabric.















The article also meets the requirements for class I according to the North American standard NFPA 260 for upholstered furniture (based on the Test Reports no. 10-002-775 A + B dated 24.11.2010).

The article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira CS fabrics also meet the requirements according to the North American NFPA Life Safety Code 101, class A, Test Standard ASTM E84 Surface Burning Characteristics, Test Report No. 12-002-527, dated August 30, 2012.

Indorama Ventures Fibers Germany GmbH (This document is valid without signature.)